

Sprinkler Coverage in Closets and Wardrobes
Effective March 26, 2007

Bureau of Fire Services Informational Interpretation PR 07-01, Sprinkler Coverage in Closets and Wardrobes for all Fully Sprinklered Facilities, in accordance with National Fire Protection Associated standards 13, 13R or 13D, regulated by the Bureau of Fire Services.

1. Built – in closets shall be protected by placing a sprinkler head inside.
2. Wardrobes over 36 cubic feet shall be protected by placing a sprinkler head inside.
3. Wardrobes 36 cubic feet and under shall be protected by placing a sprinkler head inside or placing a sprinkler head within 3 feet directly in front of the wardrobe.